


ALS Calibration Certificate



This certificate is valid for *Model* *Serial Number*
ALS50-II **SN089**

Calibration certificate issued on **06 February 2013**

by **Roberto Clerigo**

Certificate and calibration data ID **SN089 ALS Cal Report 130131**

Leica Geosystems AG
Heinrich-Wild-Strasse
9435 Heerbrugg
Switzerland



Components of ALS


Component	Device	Type	Serial Number
LS50	Laser Scanner		080
	IPAS 10		6553
	Inertial Measurement unit	CUS6 "uIRS"	56015342
DLM50	Data Logger	XP embedded	080
	Galvo Controller	"ALS_P2"	080
		performance	
SC50	System Controller		080

Calibration process

Intensity based range correction (IBRC)

	Passed	Date	Inspector
<i>RIVIT (raw IBRC) measurements</i>	ok	18 Dec 12	Phung Nguyen
<i>IBRC table</i>	ok	18 Dec 12	Phung Nguyen

File **SN89_IBRC_Dualtable_20121218.csv**
 Objective To correct for the effect of varying range based on return signal strength.
 Note The range biases are in meters. The bias values are for intensity values of 0 (low intensity) to 255 (high intensity) in that order. Use above file in ALSPP for IBRC correction.



Intensity based range correction (IBRC) - curve

Flight and data processing

	Passed	Date	Inspector
<i>Test flight</i>	<i>ok</i>	<i>31 Jan 13</i>	Phung Nguyen
<i>Data Quality Check</i>	<i>ok</i>	<i>05 Feb 13</i>	Mal Hentschel
<i>(Boresight) Calibration</i>	<i>ok</i>	<i>06 Feb 13</i>	Roberto Clerigo

File **ALS_SN080_calibrated_130123.reg**
Objective To correct for systematic effects of this ALS System.
Note It is recommended that a complete calibration be performed after system delivery to verify and establish a final set of parameters.

IPAS Processing

Parameter [Units]	Value
<i>IMU Type</i>	CUS6 "uIRS"
<i>IMU Lever Arm X [m]</i>	-0.411
<i>IMU Lever Arm Y [m]</i>	0.206
<i>IMU Lever Arm Z [m]</i>	-0.192m
<i>Omega Rotation Angle</i>	0.00000
<i>Phi Rotation Angle</i>	0.00000
<i>Kappa Rotation Angle</i>	0.00000
<i>User Frame Lever Arm X [m]</i>	-0.142
<i>User Frame Lever Arm Y [m]</i>	-0.001
<i>User Frame Lever Arm Z [m]</i>	-0.188
<i>Omega Rotation Angle</i>	0.00000
<i>Phi Rotation Angle</i>	0.00000
<i>Kappa Rotation Angle</i>	0.00000
<i>IPAS Pro IMU Latency [sec]</i>	0.000
<i>Test Airplane</i>	
<i>GPS Lever Arm X [m]</i>	0.350
<i>GPS Lever Arm Y [m]</i>	0.030
<i>GPS Lever Arm Z [m]</i>	-1.220

ALS Calibration Summary – Key Parameters for use in the ALS Post Processor

Parameter [Units]	Value
<i>Encoder Scale Factor [encoder counts per revolution]</i>	8388608
<i>Encoder Offset [encoder counts]</i>	-13797
<i>Roll [rad]</i>	0.002621928
<i>Pitch [rad]</i>	-0.00309600
<i>Heading [rad]</i>	0.000242981
<i>Pitch Error Slope [rad/deg]</i>	-1.2e-005
<i>Torsion Constant [Nm/rad]</i>	250000
<i>Nominal Range Offset [m]</i>	3.22
<i>R1 [m] BankA / BankB</i>	3.220 / 3.25
<i>R2 [m] BankA / BankB</i>	3.233 / 3.244
<i>R3 [m] BankA / BankB</i>	3.265 / 3.266
<i>R4 [m] BankA / BankB</i>	3.229 / 3.278
<i>TPR [Hz]</i>	50000
<i>TPR Offset [m]</i>	0
<i>Elevation Offset [m]</i>	0
<i>Encoder Latency [ms]</i>	0.40
<i>IMU Latency [ms]</i>	0

Accuracy Check

	Value	Std Dev	Inspector
<i>Avg Dz to Control. Bregenz 451 check points</i>	-0.001	0.036	Roberto Clerigo
<i>Summary Calibration check</i>	ok		Roberto Clerigo

Nominal Laser Characteristics

	Value
<i>Beam diameter (1/e and 1/e², mm)</i>	5.6, 8.0
<i>Beam divergence (1/e and 1/e², mr)</i>	0.15, 0.22
<i>Pulse width (maximum, Full Width Half Max, ns)</i>	9
<i>Maximum single-pulse energy (mJ)</i>	0.2
<i>Emitted wavelength (nm)</i>	1064

Inspection

Inspector

<i>Name</i>	Roberto Clerigo
<i>Position</i>	Airborne Systems Support Engineer
<i>Name</i>	Phung Nguyen
<i>Position</i>	Airborne Systems Support Engineer